

## HYDROCO TIME



- The following information is to assist the plumbing contractor in preparation for the delivery and installation of the HydroCo Time treatment capsule.
- All plumbing work performed **must** be in accordance with the local and national codes.
- An installation and user guide is supplied with the equipment.

### GENERAL DESCRIPTION

The HydroCo Time Treatment Capsule is a stand alone hydrotherapy steam/shower capsule. The HydroCo Time is supplied as a free standing unit. It is recommended to install the HydroCo Time on a tiled floor surface, or it may be installed on wooden floors if required.

	REQUIREMENTS
Hot and Cold Water Supply – ½" (12mm)	<ul style="list-style-type: none"> <li>• ½ " (12mm) hot and cold supply lines should exit the floor as shown in the floor plan provided – install shut-off valves to lines.</li> <li>• Hot and cold water supply lines are to be connected to the ½ " (12mm) female unions located under the bed.</li> <li>• Ensure water lines are purged of sand and grit etc... prior to final connection to the unit.</li> </ul>
Operating Hot Water Supply	<ul style="list-style-type: none"> <li>• An operating <b>Hot</b> water supply temperature of between 122°F (50°C) and 140°F (60°C) is required.p</li> </ul>
Water Drainage – 1½" (40mm)	<ul style="list-style-type: none"> <li>• A 1 ½ " (40mm) drain should be located as shown in the floor plan provided.</li> <li>• The unit's 1 ½ " (40mm) drain is to be connected to this floor drain.</li> <li>• An additional floor drain is recommended in the room to cater for drainage of the floor in the event that flooding occurs.</li> </ul>
Operating Pressure	<ul style="list-style-type: none"> <li>• An operating water pressure between 43.5 PSI and 145 PSI max is allowed.</li> <li>• For optimum shower performance a pressure of approximately 60-70 PSI is recommended.</li> </ul>
Water Consumption	<ul style="list-style-type: none"> <li>• The HydroCo Time has a <b>steam / shower</b> system that utilises approximately 20 gallons (80 litres) of water per 30 minute treatment.</li> <li>• Assume 16 gallons (70 litres) of this to be <b>Hot</b> water.</li> <li>• Based upon the expected number of treatments daily an appropriate hot water supply needs to be installed.</li> <li>• <b>NOTE:</b> Water consumption is based upon HydroCo treatment procedures.</li> </ul>

*Manufacturer reserves the right to amend specifications without prior notice*